1.1 CRUSHING OF OVERSIZE ROCK

The Contractor, when crushing at the ______, may reject only that rock which is larger than 400 mm diameter. All other material shall be crushed to produce the quantity and type of gravel specified. To meet this requirement, the Consultant may require that additional equipment be provided, which is capable of crushing large rock, and such a requirement shall not be grounds for a claim against the Department.