



NOTES:

1. MAXIMUM PIPE PROJECTION INTO MANHOLE - 150mm.
2. LADDER RUNGS TO BE INSTALLED 400mm FROM BOTTOM AND AT 400mm INTERVALS.
3. MANHOLE SHALL CONFORM TO A.S.T.M. SPEC C-478.
4. NOMINAL METRIC DIMENSIONS SHOWN.
5. MANHOLES WHICH EXCEED THE STANDARD DEPTH WILL BE MEASURED BY THE UNIT OF STANDARD DEPTH PLUS THE VERTICAL LENGTH IN EXCESS OF THE STANDARD DEPTH IN LINEAR METRES. MANHOLES OF LESS THAN STANDARD DEPTH WILL BE MEASURED AND PAID FOR AS A STANDARD DEPTH UNIT.
6. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE NOTED.

▲			
▲			
No.	REVISIONS	BY	DATE

<p style="text-align: center;">Approved:</p> <p style="text-align: center;">Executive Director, Roadway Engineering Branch</p>	<p>Alberta TRANSPORTATION AND UTILITIES Engineering Division</p>
<p>Date: JUNE 22, 1994</p>	

**PRECAST REINFORCED
CATCH BASIN MANHOLE
1050 mm DIAMETER**

Prepared By: LT	Checked By: B.K.	Scale: N.T.S.	Dwg No.: CB6-2.10 M24
-----------------	------------------	---------------	-----------------------