

NOTE: I. BACKFILL UNDER PIPE HAUNCHES AND IMMEDIATELY ADJACENT TO PIPE TO BE PLACED IN LAYERS NOT EXCEEDING 150mm and Thoroughly COMPACTED AT OPTIMUM MOISTURE WITH PNEUMATIC OR OTHER MECHANICAL TAMPING EQUIPMENT.

2. RIP - RAP OF TYPE AS SPECIFIED TO BE PLACED AT CULVERT ENDS.

Acorto	DWG. Nº	CB-6 2.4.M2
		Date
TRANSPORTATION	Original	May, 1979
Engineering Division	Revised	

TYPICAL
REINFORCED CONCRETE PIPE
INSTALLATION
THROUGH SIDE ENTRANCES