



NOTE: DURING SUBGRADE CONSTRUCTION, A MINIMUM OF 0.3 METRE OF COVER IS TO BE PROVIDED AND MAINTAINED OVER THE CORRUGATED METAL PIPE CULVERT TO PROTECT THE STRUCTURE FROM DAMAGE.

	DWG. N <sup>o</sup>	CB-6 2.4.M8
		Date
	Original	April, 1979
	Revised	

**TYPICAL CROSS-SECTION  
 CORRUGATED STEEL PIPE  
 CULVERT INSTALLATION  
 FOR MEDIAN DRAINAGE**