



1. ALL CONCRETE SHALL BE 40Mpa AT 28 DAYS.
2. ALL REINFORCEMENT SHALL BE EPOXY COATED REINFORCING BARS.
3. ALL EXPOSED CONCRETE SHALL HAVE A SMOOTH SURFACE.
4. EXPOSED SURFACES SHALL HAVE 20mm CHAMFER OR FILLET OR AS OTHERWISE SPECIFIED.
5. ALL SURFACES SHALL BE FORMED WITH OILED PLYWOOD OR STEEL FORMED FINISH.
6. ALL VOIDS ARE TO BE CAPPED AND WATERPROOFED
7. EXPOSED SURFACES SHALL HAVE AN APPROVED SEALING SOLUTION APPLIED

ALL DIMENSIONS ARE IN MILLEMETRES UNLESS OTHERWISE NOTED

	DWG. NO.	4.3 M1A
	DATE	1977

REINFORCED CONCRETE MEDIAN BARRIER CURB

N.J SHAPE

SUPERSEDED